



1. Membrane – FiberTite-FB, FiberTite-XT FB & FiberTite-XTreme FB
2. Adhesive – FTR-290 or ICP CR20 Spatter Applied
3. Coverboard – ½-in (13mm) APA Rated OSB SheathingAdhered
4. Approved FTR-Value Insulation Mechanically Attached or Adhered
5. Optional Vapor Barrier – Self-Adhered, Torch, & Hot Asphalt
6. Deck – Steel or Structural Concrete

## Requirements

### Slope Requirements

Positive slope required for warranty

### Construction Type

New Construction or Re-Roof w/ Complete Tear Off

### Building Height Limitation

Dependent upon design wind velocity pressure requirements. Contact FiberTite Technical Services for guidance.

### Base Tie-Ins

Must be attached to substrate to provide a minimum resistance of 250 lbf (1112 N) in any direction.

### Increased Wind Speed and Codes

Any wind speed coverage in excess of 60 mph (96 kph) or projects with specific building code requirements must be evaluated and accepted by FiberTite Technical Services.

### Deck Requirements

See approved deck types listed in RoofNav®

### Coverboard/Insulation Types

See approved coverboard and insulation types listed in RoofNav.

Minimum ½-in (13mm) APA Rated OSB (oriented strand board) sheathing.

### Coverboard/Insulation Attachment Types

See current RoofNav assemblies for approved coverboard and insulation combinations and attachment requirements.

NOTE: Maximum 4' x 4' (1.2m x 1.2m) OSB coverboards must be used when attached with FiberTite FTR 601 insulation adhesive.

### Membrane Requirements

Approved membranes are listed in FM RoofNav assemblies

- FiberTite-FB
- FiberTite-XT FB
- FiberTite-XTreme FB

### Seaming Requirements

Minimum 1½-in (38mm) wide outside heat weld on every 3-in (76mm) wide seam.

### Membrane Adhesive Requirements

Approved membrane adhesives are listed in FM RoofNav® assemblies

- ICP CR20 Spatter Applied Polyurethane Foam Adhesive
- FTR-290 Solvent Borne Adhesive

## Detail Descriptions

Wall Terminations	See FiberTite Approved Construction Details at <a href="http://www.FiberTite.com">www.FiberTite.com</a>
Curb & Wall Flashings	Curb and wall flashings must be anchored with appropriate base tie-in detail, using appropriate membrane and attachment methods. See FiberTite Approved Construction Details at <a href="http://www.FiberTite.com">www.FiberTite.com</a>
Corners	Field fabricated corner details or FiberTite injection molded corners are available. See FiberTite Approved Construction Details at <a href="http://www.FiberTite.com">www.FiberTite.com</a>
Roof Edges/Parapets	FiberTite FiberClad metal is available for roof edge transitions. Depending on wind load requirements, FiberTite AnchorTite edge and coping systems may be required. See FM RoofNav for available edge and coping systems. See FiberTite Approved Construction Details at <a href="http://www.FiberTite.com">www.FiberTite.com</a>
Penetrations	Penetrations can be flashed with FiberTite injection molded Boots, Wrapid Flash or FiberTite 60-mil non-reinforced membrane. See FiberTite Approved Construction Details at <a href="http://www.FiberTite.com">www.FiberTite.com</a>
Vapor Retarder	The use of a vapor retarder in FiberTite roof systems is project and individual design specific. Please contact the FiberTite Technical Department for recommendations on the use of a vapor retarder on your project.

## Notes

1. The use of an FM Rated Very Severe Hail (VSH) assembly does not guarantee hail coverage greater than ¾-in by Seaman Corporation
2. Hail coverage may require additional assembly enhancements and warranty premiums
3. Wind speed coverage greater than 60mph (96 kph) will require additional system enhancements
4. Fastener withdrawal testing is required for all re-roof scenarios
5. Only products provided by Seaman Corporation are covered under the FiberTite Commercial Roof Warranty
6. Visit [www.FiberTite.com](http://www.FiberTite.com) or contact your FiberTite Representative for additional information and details
7. The FiberTite Authorized Roofing Contractor is responsible for adherence to all applicable building codes and/or specification requirements
8. All proposed roof assemblies must be accepted by FiberTite Technical Services for warranty consideration prior to bidding or installation.
9. When FM Approved / Tested Assemblies or warranty requirements conflict, the more stringent assembly requirements shall be followed